

Certificate of Conformity

Certificate number: CM40195

Certification Body:


 ABN: 80 111 217 568
 JAS-ANZ Accreditation
 No. Z4450210AK
 PO Box 7144, Sippy
 Downs Qld 4556
 +61 (07) 5445 2199
 www.CertMark.org

Certificate Holder:

Metecno Pty Ltd
 T/A Metecno,
 Bondor®
 ABN: 44 096 402 934
 121 Ingram Road,
 Acacia Ridge Qld 4110
 Ph: +61 7 3323 8555
 www.bondor.com.au

THIS IS TO CERTIFY THAT

Equideck®

Type and/or use of product:

Insulated Roof Panel.

Description of product:

Equideck® is an insulated roof panel comprising Expanded Polystyrene with Fire Retardant (EPS-FR) core and Colorbond steel skins. Refer A2 for further information.

COMPLIES WITH THE FOLLOWING BCA PROVISIONS AND STATE OR TERRITORY VARIATION(S)

BCA 2019 (Amdt. 1)

	Volume One	Volume Two
Performance Requirement(s):	BP1.1(a)& (b)(i),(ii)&(iii)	P2.1.1(a), (b)(i),(ii),(iii)
	Structural reliability	Structural stability and resistance to actions
Deemed-to-Satisfy Provision(s):	C1.10(a)(ii) &(ix)	P2.2.2
	Fire Hazard Properties – Refer A3.	Weatherproofing – Roof applications
	F1.5	3.12.1.2
	Weatherproofing – Roof coverings	Energy Efficiency - Roof construction can contribute to the Total R Value. Refer to A3.
	J1.3	
	Roof and Ceiling Construction – Can be used in conjunction with other building elements to achieve a Total R Value. Refer A3.	
State or territory variation(s):	Not Applicable	Part 3.12 (NSW, NT, SA, Qld, Tas, ACT)

SUBJECT TO THE FOLLOWING LIMITATIONS AND CONDITIONS AND THE PRODUCT TECHNICAL DATA IN APPENDIX A AND EVALUATION STATEMENTS IN APPENDIX B



Richard Donarski – CMI



Don Grehan – Unrestricted Building Certifier

Date of issue: 24/03/2021

Date of expiry: 24/03/2024



Certificate of Conformity

Limitations and conditions:

1. The roof panels will be limited by wind load shown in the manufacturer's specifications on the span certified for the product type, thickness, core density and fixing configuration as per the product's certified span tables, refer A3.
2. The size and location of any penetration through the Equideck[®] panels must be in accordance with Drawing [EDE03-RP01-00 ROOF PENETRATIONS - EQUIDECK- RO](#). Penetrations for flues, chimneys or exhaust of hot products of combustion are outside the scope of this certificate and require site-specific solutions. Contact Certificate Holder for site-specific solutions.
3. This product has not been tested to AS 1530.1-1994 (R2016) and cannot be considered a non-combustible product.
4. In the absence of a site-specific performance solution, this product or system must not be used to facilitate the exemptions for a carport specified in Part 3.7.2.6(d) of Volume 2 of the BCA.
5. The structural support members are designed and engineered separately as per project requirements by building designers and engineers.
6. The Group numbers achieved in accordance with AS ISO 9705-2003 (R2016) as either Group 2 or Group 1 depending on the thickness and construction detail, refer A3.
7. The Equideck[®] panel as a Group 2 fire rated product, is only suitable for use as a ceiling lining as specified in Table 3 of Specification C1.10 of the BCA 2019.
8. This certificate is limited to the details within this certificate including the above compliance elements, product description, purpose or use.
9. It is the responsibility of the building designer to ensure fitness for purpose including, but not limited to, consideration for the corrosion resistance level of the product and the proximity to breaking surf.
10. The use of the certified product/system is subject to these Limitations and Conditions and must be read in conjunction with the Scope of Certification below.

Building classification/s:

Class 1,2,3,4,5,6,7,8,9 & 10

Scope of certification: The CodeMark Scheme is a building product certification scheme. The rules of the Scheme are available at the ABCB website www.abcb.gov.au. This Certificate of Conformity is to confirm that the relevant requirements of the Building Code of Australia (BCA) as claimed against have been met. The responsibility for the product performance and its fitness for the intended use remain with the Certificate Holder. The certification is not transferrable to a manufacturer not listed on Appendix A of this certificate.

Only criteria as identified within this Certificate of Conformity can be used for CodeMark certification claims. Where other claims are made in a client's Installation Manual, Website or other documents that are outside the criteria on this Certificate of Conformity, such criteria cannot be used or claimed to meet the requirements of this CodeMark certification.

The NCC defines a Performance Solution as one that complies with the Performance Requirements by means other than a Deemed-to-Satisfy Solution. A Building Solution that relies on a CodeMark Certificate of Conformity that certifies a product against the Performance Requirements cannot be considered as Deemed-to-Satisfy Solution.

This Certificate of Conformity may only relate to a part of a Performance Solution. In these circumstances other evidence of suitability is needed to demonstrate that the relevant Performance Requirements have been met. The relevant provisions of the Governing Requirements in Part A of the NCC will also need to be satisfied.

This Certificate of Conformity is issued based on the evidence of compliance as detailed herein. Any deviation from the specifications contained in this Certificate of Conformity is outside of this document's scope and the installation of the certified product will not be covered by this Certificate of Conformity. This may result in the product being classified as a non-conforming building product.

Disclaimer: The Scheme Owner, Scheme Administrator and Scheme Accreditation Body do not make any representations, warranties or guarantees, and accept no legal liability whatsoever arising from or connected to, the accuracy, reliability, currency or completeness of any material contained within this certificate; and the Scheme Owner, Scheme Administrator and Scheme Accreditation Body disclaim to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this certificate.

When using the CodeMark logo in relation to or on the product/system, the Certificate Holder makes a declaration of compliance with the Scope of Certification and confirms that the product is identical to the product certified herein. In issuing this Certificate of Conformity, CertMark International has relied on the experience and expertise of external bodies (laboratories and technical experts).

Nothing in this document should be construed as a warranty or guarantee by CMI, and the only applicable warranties will be those provided by the Certificate Holder.


APPENDIX A – PRODUCT TECHNICAL DATA

A1 Type and intended use of product

As per page 1.

A2 Description of product

Core	EPS-FR (Expanded Polystyrene SL Grade with fire retardant) SL Grade
Width (cover mm)	1200
Thickness (mm)	50, 75, 100, 125, 150, 200 & 250
Length	Up to 16m
External Material	BlueScope® Colorbond® Steel 0.6mm G300
Internal Material	BlueScope® Colorbond® Steel 0.6mm G300
Pitch	3° Minimum



A3 Product specification

Structure & Weatherproofing In order to maintain compliance with structure, the following Span Tables must be referred to which have been certified by a licensed Professional Engineer in accordance with AS 1562.1, AS/NZS 1170.0, AS/NZS 1170.1, AS/NZS 1170.2, AS 4055 & AS 4040.1..

Document Name	Version
EQUIDECK® SPAN TABLES FOR WIND REGION A & B – NON-CYCLONIC (EXTERNAL ROOF APPLICATIONS ONLY) EPS-FR Core Grade SL 0.6/0.6mm steel skins	5
EQUIDECK® SPAN TABLES FOR WIND REGION A & B – NON-CYCLONIC (EXTERNAL ROOF APPLICATIONS ONLY) EPS-FR Core Grade SL 0.6/0.6mm steel skins – Tek Screw	5
Equideck EPS-FR Core Grade SL 0.6mm Steel Skins - Roof Span Table for Housing Application EQUIDECK® 0.6mm Steel Skins - Roof Span Table for Housing Application	4

Penetrations

In order to maintain compliance with structure, the following document must be referred to which has been certified by a licensed Professional Engineer; [Drawing EDE03-RP01-00 ROOF PENETRATIONS - EQUIDECK-RO](#). The adequacy of the size, location and spacing of any penetrations outside the scope of this document through the Equideck® panel must be confirmed by a structural engineer.

Material Group Numbers

Group 1:

Panel up to 250mm thick with steel 'wall-wall' and 'wall-ceiling' angles fixed with steel rivets or screws at maximum 300mm centres is classified as Group 1.

Smoke Growth Rate (SMOGR_{RC}) Index was 2.4 m²/s².

Group 2:

Panel up to 250mm thick with aluminium 'wall-wall' and 'wall-ceiling' angles fixed with aluminium rivets or screws at 300mm centres is classified as Group 2.

Smoke Growth Rate (SMOGR_{RC}) Index was 12.0m²/s².

Fire Hazard Properties

AS/NZS 1530.3-1999 Indices

Ignitability Index	0	Range 0-20
Spread of Flame Index	0	Range 0-10
Heat Evolved Index	0	Range 0-10
Smoke Index	2	Range 0-10

Source: AWTA Product Testing Report No. 7-563460-CQ dated 25/11/2008.

Thermal & Energy Efficiency

Equideck EPS-FR core SL Grade

Thickness (mm)	$\lambda_{\text{declared}}$ at 23°C (W/m.K)	R_{declared} at 15°C(m ² .K/W)	R_{declared} at 23°C(m ² .K/W)	Roof Total R-value (m ² .K/W) at		
				6°C	15°C	30°C
50	0.042	1.25	1.20	1.44	1.40	1.38
75	0.042	1.85	1.80	2.09	2.03	1.98
100	0.042	2.45	2.40	2.73	2.65	2.57
125	0.042	3.10	3.00	3.37	3.27	3.17
150	0.042	3.70	3.60	4.02	3.90	3.76
200	0.042	4.95	4.85	5.30	5.15	4.95
250	0.042	6.20	6.05	6.59	6.40	6.13

Notes:

- Declared R-values are Product R-values and exclude air film resistances.
- Total R-values include default air film resistances for the applications.
- The results are compliant with AS/NZS 4859 Parts 1&2:2018, Thermal insulation materials for buildings, hence they are compliant with NCC2019 Volumes One and Two.

Source: James Fricker Report No. i265e updated 21/02/2021.

A4 Manufacturer and manufacturing plant(s)

This field is optional. Contact Certificate holder for manufacturing locations.

A5 Installation requirements

Installation requirements are outside the scope of this certificate and subject to project specific engineering advice. The minimum fixing requirements are outlined in the Span Tables referenced in A3 of this Certificate of Conformity.

A6 Other relevant technical data

No other relevant technical data

APPENDIX B – EVALUATION STATEMENTS

B1 Evaluation methods

1. Fire Safety Provisions A5.2(1)(d)&(e). Reports from Accredited Testing Laboratories and a professional engineer.
2. Structural Provisions A5.2(1)(d)&(e). Reports from Accredited Testing Laboratories and a professional engineer.
3. Thermal Provisions A5.2(1)(e). Reports from a professional engineer.
4. Weatherproofing Provision A5.2(1)(e). Reports from a professional engineer.

B2 Reports

1. AWTA; NATA Accreditation No.983; Test Report No. 7-563460-CQ; Testing in accordance with AS/NZS 1530.3:1999 - Fire Indices; Dated 25/11/2008.
2. Blight Tanner; Reference No. 2017.0493; Certification of Equideck® in accordance with AS 1170.0:2002, AS 1170.1:2002, AS 1170.2:2011, AS 4040.1-1992 & AS 1562.1:2018; Dated 04/02/2021.
3. CSIRO; Report No. CMIT-(C)-2004-089; Assessment of the performance of sandwich panels ISO 9705 Testing; Dated March 2004.
4. Ignis Solutions; Evaluation No. IGNS-5396 Issue 02 Revision 00; Assessment of Bondor panels ISO 9705 Testing; Dated 21/09/2019.
5. James M Fricker Pty Ltd; Document No. i265e; Declared R (thermally bridged) thermal performance calculations to AS/NZS 4859 Parts 1 & 2:2018; Updated 22/02/2021.

The Certificate Holder has chosen not to make the above evidence of compliance publicly available, due to the documents being considered commercial in confidence.